VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	05 - Southeast Kootenay
School Name:	Mount Baker Secondary School
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2024-09-18
	Date of next inspection: 2024-10-18
	Date and type of most recent maintenance: We check our school's ventilation at least once a month and have a 3-month filter change PM. That said we are constantly inspecting our HVAC systems when we are in the schools.
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: We increased the air flow to the Ashre recommended levels.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): On the recommendation of our engineers, we have not gone to Merv 13. This school is served with 7 rooftop units which use Merv 10 filters, three makeup air roof top units which use Merv 10 filters and 4 inside Make up air units which use Merv 10 filters.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: Yes
	Detail: -We have left Air purifiers in the majority of the rooms. -Complete clean, scrub and disinfect of all ducting and air handling equipment to each school. This is to be conducted every five years.
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: -We use DDC controls and have increased air flow into the buildings.
Other Relevant Information:	New boilers were installed in the Gym a couple of years ago. The air ducts were cleaned throughout the school in 2022 and are schedule again for 2027

District Contact for any Questions:	Name: Joe Tank
	Phone Number: 250-417-2068
	Email: joe.tank@sd5.bc.ca